



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Unscreened Class E / Category 6 Permanent Link

Legrand
128 Avenue de Lattre de Tassigny
F-87045 Limoges Cedex, France

Attestation of Conformity No. 102187

This type of Class E / Category 6 unscreened permanent link has been tested by 3P Third Party Testing and complies with the Class E permanent link requirements of the proposed 2nd Editions of ISO/IEC 11801 and CENELEC EN 50173, Class D permanent link requirements of ISO/IEC 11801 ed. 1.2 and CENELEC EN 50173/A1, Category 6 permanent link requirements of draft ANSI/TIA/EIA-568-B.2-1 and Category 5e permanent link requirements of ANSI/TIA/EIA-568-B.2. The Attestation of Conformity is valid for the actually tested permanent link sample in T568B designation connected to test equipment with RJ 45 plug from Legrand patch cord, type 051770/71/72/73/74 and consisting of the following components:

<i>Cable from Legrand:</i>	<i>Horizontal Cable,</i>	<i>Type 032755</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw. from Legrand:</i>	<i>Connection Module,</i>	<i>Type AL51 having PCB Marking 6G1 1202</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 25 July 2002

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 25 July 2002

Paul Villien

Poul Villien
Coordinating Manager